

COUNCIL COMMUNICATION

TO:	THE CITY COUNCIL	COUNCIL MEETING DATE	NO.
FROM:	THE CITY MANAGER'S OFFICE	JUNE 6, 1990	
SUBJECT:	APPROVE SPECIFICATIONS AND ADVERTISE FOR BIDS FOR PADMOUNT TRANSFORMERS		

RECOMMENDED ACTION: That the City Council approve the specifications and authorize the advertisement for bids for 21 padmounted transformers.


BACKGROUND INFORMATION: The Electric Utility Department has requested that the following padmounted transformers be purchased to support various projects and to replenish inventory:

KVA - VOLTAGE	<u>SINGLE-PHASE</u>	<u>THREE-PHASE</u>
50 240/120	7	-
100 240/120	8	-
112.5 480Y/277	-	1
150 480Y/277	-	1
225 480Y/277	-	2
300 480Y/277	-	1
750 480Y/277	-	1
TOTALS	15	6

Some of the projects using these transformers include the Maggio Industrial Subdivision, Griffin Industrial Park, Almondwood Subdivision, and the Industrial Substation. The transformers will also be used for budgeted distribution system improvements, and to provide inventory for emergency replacements.

The estimated cost of this purchase is \$63,000, with funding available in the Electric Utility Department's operating fund.

The bid opening has been set for Tuesday, July 3, 1990.



 Joel E. Harris, Purchasing Officer

cc: Electric Utility Director
 Assistant Electric Utility Director
 Electrical Engineer